

VOC Content Test Certificate

Monday, 23th May 2016

Manufacturer: Spirits Marble & Tile Care Pty Ltd (1/36 Seton Road, Moorebank, NSW, 2170).

Sample Description: Spirits Water Based Premium Seal

Date Tested: May 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

| | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
| <p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p> | <p>Spirits Water Based Premium Seal</p> |
| <p>General Purpose Adhesive and Sealants: 50 grams per Litre as VOC content per material</p> | <p><1 grams per Litre as VOC content per material</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160544